



Certificate of Compliance

Certificate:	70126847	Master Contract:	263009
Project:	80280938	Date Issued:	2026-03-30
Issued to:	GIZMO Products Inc. 3 North Newark St. Phelps, New York 14532 United States	Issued by:	<i>Blake Apathy</i> Blake Apathy, Product Safety Engineer

Attention: Peter Blokhuis

The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US or with adjacent indicator 'US' for US only or without either indicator for Canada only.



PRODUCTS

Class 2258 04 PROCESS CONTROL EQUIPMENT - Intrinsicly Safe, Entity - For Hazardous Locations

Class 2258 84 PROCESS CONTROL EQUIPMENT - Intrinsicly Safe, Entity - For Hazardous Locations - Certified to US Standards

Ex ia IIB T4 Ga

Class I, Zone 0, AEx ia IIB T4 Ga

Class I, Div. 1 Groups C and D T4

IP65

$-40^{\circ}\text{C} \leq \text{Tamb} \leq +60^{\circ}\text{C}$

Alarm Box IS-AB, Tank Alarm IS-T, and Drum Alarm IS-D are battery operated devices with maximum input voltage of 7.2Vdc derived from battery pack model BT-IS. The operating temperature range is $-40^{\circ}\text{C} \leq \text{Tamb} \leq +60^{\circ}\text{C}$. The device is for use in hazardous location and provides intrinsically safe connections to relay contacts and *to the simple apparatus (passive component)*



Certificate: 70126847

Master Contract: 263009

Project: 80280938

Date Issued: 2026-03-30

contacts, which are illustrated as level switches in the control drawing IS-001. The Alarm device Input Entity Parameters are: $V_{max} = 28V_{dc}$, $I_{max} = 100mA$, $P_{max} = 700mW$, $C_i = 0$ and $L_i = 0$.

Product Nomenclature:

Alarm Box (IS-AB)

I S - A B - *

Options _____

(blank if none)

Tank Alarms (IS-T)

I S - T * - * * - * * - *

H or L _____

Material _____

Length _____

Options _____

(blank if none)

Drum Alarms (IS-D)

I S - D * * - * * - * * G - *

H or L _____

Mounting _____

Material _____

Length _____

Options _____

(blank if none)

Note:

1. Environmental Conditions: Outdoor, -40°C to +60°C, 2000m max.

Conditions of Acceptability:

1. For safe installation of the device, refer to the Alarm Instruction document; Instructions - IS-AB, IS-T, and IS-D.
2. Only Intrinsically Safe battery package BT-IS must be used with Drum Alarm models IS-AB, IS-T and IS-D.
3. The Relay output contact terminals shall connect to a certified I.S. Barrier only.
4. The enclosure of Alarm models IS-T and IS-D are made from Aluminum. In rare cases, ignition sources due to impact and friction sparks could occur. This shall be considered during installation and use. Use care not to cause impacts or scrapes with other metal objects during installation.
5. Under certain extreme circumstances, exposed plastic and unearthed metal parts of the enclosure of models IS-T, IS-D may store an ignition capable of an electrostatic charge. Therefore, the user/installer shall implement provisions to prevent the buildup of electrostatic charge, i.e. locate the equipment where a charge-generating mechanism is unlikely to be present, and clean with a water-moistened cloth.
6. Simple Apparatus (passive component) is permitted for connection with models IS-AB, IS-T or IS-D, provided that the end user



Certificate: 70126847

Master Contract: 263009

Project: 80280938

Date Issued: 2026-03-30


must comply with the following conditions:

- the Simple Apparatus switches are used within their ratings
- the Entity parameters of Drum Alarm device are regarded and correctly applied when connecting the Simple Apparatus switch.
- the Simple Apparatus switch used with any Drum Alarm models IS-AB, IS-T or IS-D shall not form or considered part of the Drum Alarm device.

APPLICABLE REQUIREMENTS

Standards Used	Description
CSA C22.2 No. 60079-0:15 - Third Edition	Explosive atmospheres — Part 0: Equipment — General requirements
CAN/CSA C22.2 No. 61010-1-12	Safety requirements for electrical equipment for measurement, control, and laboratory use — Part 1: General requirements
CAN/CSA-C22.2 No 60079-11:14	Explosive Atmospheres - Part 11: Equipment protection by intrinsic safety 'i'
ANSI/ISA 60079-0 (12.00.01) - 2013 - Sixth Edition	Explosive atmospheres - Part 0: Equipment - General Requirements
UL 913(Eighth Edition)	UL Standard for Safety Intrinsically Safe Apparatus and Associated Apparatus for Use in Class I, II, and III, Division 1, Hazardous (Classified) Locations - Eighth Edition
ANSI/ISA 60079-11 (12.02.01):2012 - 6th Edition	Explosive Atmospheres – Part 11: Equipment protection by intrinsic safety “I”
ANSI/UL 61010-1:2012 - Third Edition	Electrical Equipment For Measurement, Control, and Laboratory Use; Part 1: General Requirements

Markings

- CSA Monogram with C-US indicator.
 - Submitter Identification or CSA master contract number 263009
 - Model Number IS-AB, or IS-T or IS-D Alarm
 - Serial Number, Date Code or Month and Year of Manufacture
 - Battery model BT-IS
 - Hazardous Location Designation as per product listing
 - Ambient temperature range as per product listing
 - The wording: “Intrinsically Safe” and “Sécurité Intrinsèque” or the symbol “Ex ia”
 - Warning statements below or if there is space limitation, a reference to instruction manual using symbol  .
- “WARNING - Only Intrinsically Safe battery package BT-IS must be used with Drum Alarm models IS-AB, IS-T and IS-D.”

“WARNING - Potential electrostatic charging hazard – see instruction



Certificate: 70126847


Master Contract: 263009

Project: 80280938

Date Issued: 2026-03-30

Notes:

Products certified under Class(es) C225804, C225884 have been certified under CSA's ISO/IEC 17065 accreditation with the Standards Council of Canada (SCC). www.scc.ca





Supplement to Certificate of Compliance

Certificate: 70126847

Master Contract: 263009

*The products listed, including the latest revision described below,
are eligible to be marked in accordance with the referenced Certificate.*

Product Certification History

Project	Date	Description
80280938	2026-03-30	Evaluation to update cCSAus report # 70126847 (last project 80201322) for intrinsically safe "ia" protected Alarm Box IS-AB, Tank Alarm IS-T, and Drum Alarm IS-D for addition of alternate potting compound 834HTC.
80201322	2024-03-18	Update to Report 70126847 for Alarm Box IS-AB, Tank Alarm IS-T, and Drum Alarm IS-D to improve the sound volume from piezoelectric buzzer by revising components on the main board.
80103514	2022-01-10	Update of cCSAus report # 70126847 for Alarm Box IS-AB, Tank Alarm IS-T, and Drum Alarm IS-D to correct few typographic errors for conduit body model designation, main enclosure manufacturer, marking and labelling system part number, and warble tone circuit model number.
70210677	2019-01-28	Update CSA report 70126847 to allow the use of simple apparatus switches for providing signal to the Alarm system when used within the entity parameter specifications.
70181458	2018-04-26	Update CSA report 70126847 to include an additional standard UL-913 Ed.8.
70161199	2018-01-17	Update to CSA Report 70126847 to make the previously certified model names changed to IS-AB and IS-T, to include a variation model IS-D, to make minor changes to the buzzer circuit to improve performance, to give IP65 rating to models IS-T and IS-D, and to update descriptive documents.
70126847	2017-09-12	Original cCSAus certification for Drum Alarm Models AB-IS and T-IS as Intrinsically Safe for Ex ia IIB T4 Ga and Class I Div.1 with Ta max = 60°C with battery model BT-IS.